

# Attestation

## AgBB

On the 10<sup>th</sup> of October 2022, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

**HVU2**

supplied by

**Hilti Entwicklungsgesellschaft mbH**

The emissions were tested according to AgBB (AgBB - Committee for Health-related Evaluation of Building Products). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, and ISO 16000-11 (see the test report no. 392-2022-00443504\_D\_EN).

### **Evaluation of the emission test result according to AgBB:**

---

- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC ("TVOC") after 3 days was in compliance with the limit of  $\leq 10$  mg/m<sup>3</sup>.
- The sum of VOC ("TVOC") after 28 days was in compliance with the limit of  $\leq 1$  mg/m<sup>3</sup>.
- The sum of SVOC after 28 days was in compliance with the limit of  $\leq 0.1$  mg/m<sup>3</sup>.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5  $\mu$ g/m<sup>3</sup>. This value R was in compliance with the limit of  $\leq 1$ .
- The sum of VOC without LCI-value after 28 days was in compliance with the limit of  $\leq 0.1$  mg/m<sup>3</sup>.
- The concentration of formaldehyde after 28 days was in compliance with the limit of  $\leq 0.1$  mg/m<sup>3</sup>.

---

**The tested product complies with the requirements of AgBB including the LCI-values (June 2021) for use in the indoor environment.**

6 December 2022



Liva Kjær Hansen  
Analytical Service Manager



Laura Hartung Sørensen  
Analytical Service Manager